



Town of Gananoque

May 24, 2022

---

**Request for Quotations No. CS-2022-07**  
**Aerating Fountain**  
**Addendum #2**

---

This Addendum is being issued to clarify questions submitted in regards to the RFQ documents.

1. Questions around power source. Note: There will be a 200amp 3ph 120/208v 4w outdoor service with a 200amp panel. This will be completed by the Town's electrical contractor and Eastern Ontario Power in advance of the Fountain Installation.

Bidders are instructed to include this addendum with their bid submission.

**TOWN OF GANANOQUE**  
30 King Street East  
Gananoque, ON K7G 2T6  
Phone: (613) 382-2149 ext. 1113  
Fax: (613) 382-8587